



Gary Warren
Fire Chief

City of League City Fire Marshal Plan Review



Tommy Cones
Fire Marshal/Asst. Fire Chief

Fire Department Connection Sign Specifications



Example Only

As per 2015 Edition of the International Fire Code Section 912.4

1. **Metal sign**
2. **Red background.**
3. **White reflective letters and numbers.**
4. **First line 6" high letters (F.D.C.).**
5. **Second line 3" high letters (STANDPIPE).**
6. **Third line 4" high numbers (1110 - Street Numbers).**
7. **Fourth line 3" high letters (NASA Parkway - Street Name).**
8. **¼" space between top of sign and first line.**
9. **½" space between first line and second line.**
10. **½" space between second line and third line.**
11. **½" space between third line and fourth line.**
12. **¼" space between fourth line and bottom of sign.**
13. **Letter and number font to be a block style or similar.**
14. **Spacing between words shall equal one letter size.**
15. **Spacing between F.D.C. shall be period or decimal point only.**
16. **Secure sign 36" behind F.D.C. on a two metal pole(s) mounted at least 60" above the ground to the top of the sign.**
17. **F.D.C sign shall be facing the roadway and visible from both travel directions. Two sign maybe required if the FDC is installed to face the structure.**

Guidelines may be modified with written approval from the League City Fire Marshal's Office.

